## Summary of Legislative Incentives for Fire Sprinklers in New Buildings+ Construction Alternatives are in red

	Major airports sprinklered?	Places of assembly	Shopping Centres	Industry	Warehouses	Hotels	Care Homes	Hospitals	Teaching Establishments	Residential Accommodation	Offices	Car Parks
Austria	No		>2,400m <sup>2</sup> across 3 or more storeys; >3,000m <sup>2</sup>	>5,000m <sup>2</sup> or >7,500 m <sup>2</sup> with fire resistance	>1800m <sup>2</sup> or stored goods height > 9m	>32m >22m reduced fire resistance		>32m >22m reduced fire resistance		>32m high >22m reduced fire resistance	>32m high >22m reduced fire resistance	>1,600m <sup>2</sup> with natural ventilation instead of fire detection or to reduce air changes by 75% with mechanical ventilation; >4800m <sup>2</sup>
Belgium	Yes	>3,500m <sup>2</sup> >2,500m <sup>2</sup> if Floor >10m	>2,000m <sup>2</sup>	>25,000m <sup>2</sup> and < 350 MJ/m <sup>2</sup> >10,000m <sup>2</sup> and > 350 MJ/m <sup>2</sup> >5,000m <sup>2</sup> and > 900 MJ/m <sup>2</sup>	>5,000m <sup>2</sup>	>3,500m <sup>2</sup> >2,500m <sup>2</sup> if >10m		>3,500m <sup>2</sup> >2,500m <sup>2</sup> & >10m				Automatic enclosed with LPG vehicles
Croatia	Yes	As in NFPA 101 Reduction of 30' in compartment fire	As in NFPA 101 or TRVB 138 Reduction of 30' in compartment fire	Depending on the area and number of connected floors	>9m storage; >1,000 m <sup>2</sup> and >2GJ/m <sup>2</sup> >3,000 m <sup>2</sup> and >1 GJ/m <sup>2</sup> Alternative to detection and/or smoke ventilation in smaller			As in NFPA 101 or TRVB 132 30 min less fire resistance and one	30 min less fire resistance and one	resistance and one class lower reaction to fire	30 min less fire resistance and one	As for NFPA 88a or OIB 2.2 Beneath hotels
		resistance and one grade in fire reaction class	resistance and one grade in fire reaction class		areas and lower fire loads	from 10 m to 15m	class lower reaction to fire	class lower reaction to fire				Deneaur noters
Czech Republic	No	Exhibition halls with compartment > 5,000m <sup>2</sup>	>1,000m <sup>2</sup>	>20m <sup>3</sup> of flammable liquids	Postal stores >800m <sup>2</sup> >50m <sup>3</sup> of flammable liquids	>30m				>8 storeys; >4 storeys & >50 apartments semi-combustible structure & >5 storeys & >30 apartments combustible structure & >3 storeys & >20 apartments		Automatic underground; From 2nd underground floor if >50 vehicles; Capacity >200 vehicles & below assembly buildings
Denmark	Yes	>2,000m <sup>2</sup> >1,000 m <sup>2</sup> without smoke extraction	>2,000m <sup>2</sup> >1,000 m <sup>2</sup> without smoke extraction	>2,000m <sup>2</sup> and >200MJ/m <sup>2</sup> >5,000m <sup>2</sup> other fire load	>2,000 $m^2$ and >200MJ/ $m^2$ >5,000 $m^2$ other fire load		>1,000m <sup>2</sup> sleeping area multi-floor	>1,000m <sup>2</sup> sleeping area multi-floor			Alternative to fire alarm if compartment >2,000m <sup>2</sup>	t >2,000m <sup>2</sup> except residential
Finland	Yes	2,400 m <sup>2</sup>	2,400 m <sup>2</sup>	2,000 m <sup>2</sup> if no structural fire resistance; 4,000 m2 with R30 structural fire resistance	2,000 m <sup>2</sup> if no structural fire resistance; 4,000 m2 with R30 structural fire resistance	>56 m; >28 m with R90 structural fire resistance instead of R120; timber-framed hotels 3-8 storeys	Usually required in new & existing care homes following risk assessment; timber-framed care homes 3-8 storeys	resistance instead o	1	>56 m; >28 m with R90 structural fire resistance instead of R120; timber-framed apartment buildings 3-8 storeys	>56 m; >28 m with R90 structural fire resistance instead of R120; timber-framed offices 3-8 storeys	
France	No		>3,000m <sup>2</sup> or with restaurant or >10,000kg paint Can increase storage of dangerous goods from 1,000 m <sup>3</sup> to 2,000 m <sup>3</sup>		>3,000m <sup>2</sup> and less than 12,000m <sup>2</sup> >12,000m <sup>2</sup> with risk assessment and approval from Prefect	>200m or >480 MJ/m <sup>2</sup>					>200m or >480 MJ/m <sup>2</sup>	R90 instead of R120 structural fire resistance R60 if no building above Reduce smoke ventilation by a third >3,000 m <sup>2</sup> per floor >2 underground levels
Germany	Yes	>3,600m <sup>2</sup> * total with rooms >400m <sup>2</sup> or >22m high or below ground	>3000m <sup>2</sup> or underground floors >500m <sup>2</sup> 60 minutes less fire resistance for walls and ceilings; no need for smoke extraction; can increase travel distance by 35m	Increase compartment area 3-10 times depending on fire resistance and number of storeys 1,800m <sup>2</sup> to 10,000m <sup>2</sup> ; single storey 3,000m <sup>2</sup> to 10,000m <sup>2</sup> ; single storey with 30' fire resistance	>1,200m² require 5m aisle >4,500 m² Storage > 7.5m high	>3,600m <sup>2</sup> * total with rooms >400m <sup>2</sup> or >22m high			>22m high or >32m high with balconies to prevent external fire spread and rooms <400m <sup>2</sup>	>22m high or >32m high with balconies to prevent external fire spread and rooms <400m <sup>2</sup>	>22m high or >32m high with balconies to prevent external fire spread and rooms <400m <sup>2</sup>	Floors 4m below ground Car parks under other use buildings
Greece		>50 people and >23m	>1,000m <sup>2</sup> per storey Total area >2,500m <sup>2</sup> basement >250m <sup>2</sup>	>2,000 MJ/m <sup>2</sup> or >1,000 MJ/m <sup>2</sup> and >2,000m <sup>2</sup>	>2,000 MJ/m <sup>2</sup> or >1,000 MJ/m <sup>2</sup> and >2,000m <sup>2</sup>	>28m	>100 beds >12m	>100 beds >12m	Basements >250m <sup>2</sup> Boiler rooms	>28m	>20m and >400 people	) Underground and >300m <sup>2</sup> or multi-storey
Hungary		Cinemas> 13.65m or >1,000 people	>8,000m <sup>2</sup> >13.65m height		>7,000m2	>14m	>3 storeys	If beds >13.65m	>30m	>13.65m	>30m	Multi-floor underground; >13.65m height closed; >20 cars per compartment
Ireland	No		Single storey >4000m <sup>2</sup> All shopping centres		Single storey 14,000m <sup>2</sup> normal and >1,000m <sup>2</sup> high hazard	>30m and phased evacuation					>30m and phased evacuation	
Italy	No	>16,000 m <sup>2</sup> Longer travel distances and narrower escape routes	>16,000 m <sup>2</sup> I Longer travel distances and narrower escape routes	>32,000 m <sup>2</sup> Longer travel distances and narrower escape routes	>16,000 m <sup>2</sup> Longer travel distances and narrower escape routes	>1,000 beds >8,000 m <sup>2</sup> Longer travel distance, narrower escape route	>8,000 m <sup>2</sup> Longer travel distance, narrower escape route	>8,000 m <sup>2</sup> Longer travel, narrower escape route	Basements with fire loading >30 kg/m <sup>2</sup>		Archives >200m <sup>2</sup> or >60kg/m <sup>2</sup> fire load	Multi-floor underground Above ground: '-4 floors closed '-5 floors open Automatic car parks

## Summary of Legislative Incentives for Fire Sprinklers in New Buildings+

Construction Alternatives are in red

	Major airports sprinklered?	Places of assembly	Shopping Centres	Industry	Warehouses	Hotels	Care Homes	Hospitals	Teaching Establishments	Residential Accommodation	Offices	Car Parks
Lithuania	Yes	>5000 people	>1,500m <sup>2</sup>	>2,000m <sup>2</sup> if combustible goods stored	>2,000m <sup>2</sup> or > 5.5m storage height	>26.5m	≥ 42 m or >5000 people	≥ 42 m or >5000 people	≥ 42 m or >5000 people	> 75m	≥ 42 m	Above ground >7m Automatic car parks
Luxemburg			>3,000m <sup>2</sup> or >3 storeys and >1,000m <sup>2</sup> Single storey no need for 90' structural fire resistance No need for 60' separation between units in centre			>60m high Closed car parks with >20 cars Double compartment to 1,600m <sup>2</sup>	If living areas open onto corridors			stored in building		Closed or underground with >50 cars Increase travel distance 30m to 40m if >20 cars
Netherlands	Yes		Firework sales or storage >1000m <sup>2</sup> fire compartment	>1000m <sup>2</sup> fire compartment >10,000 kg dangerous goods	Firework storage >2,500m <sup>2</sup> fire compartment >10,000 kg dangerous goods	>70m high				>70m high Reduce fire resistance from 30 to 60 minutes or increase travel distance and compartment size or fit fewer hydrants	>70m high	lf >1,000m <sup>2</sup>
Norway	Yes	>1800m <sup>2</sup> one floor	>1,200m <sup>2</sup> multi-floor	>800m <sup>2</sup> unless unusually low fire load	>800m <sup>2</sup> unless unusually low fire load	All new hotels	All new care homes	All new hospitals		All new dwellings with more than two storeys	Compartment >1800m <sup>2</sup>	>1800m <sup>2</sup> one floor
Poland		>600 people or sports stadia >3000 people	>10,000m <sup>2</sup> one floor >2,500m <sup>2</sup> multi-floor			>55m high				>55m high	>55m high	Underground & >100 cars
Portugal	No	>28m high >1,000 people >15,000m <sup>2</sup>	>28m high >1,000 people >2 storeys			>9m high >100 people >50 sleeping guests					>28m high >1,000 people	>9m, >3,200m <sup>2</sup> >1 underground storey
Serbia	Yes	>1,500 m <sup>2</sup>	>2,000 m <sup>2</sup>	Tycally >1,500 m <sup>2</sup> , depending on many factors	Flammable goods	>30m		All new hospitals		>30m	>30m	Enclosed if >1,500 m <sup>2</sup>
Slovak Republic		Exhibition halls with compartment > 5,000m <sup>2</sup>	>2,000m <sup>2</sup> one floor >1,000m <sup>2</sup> multi-floor		Yes, depending on many factors	>300 guests	>800 patients	>800 patients		>500 residents		
Spain	Yes	Increase travel distance 25%	Compartment >1,500m <sup>2</sup> and fire load >500 MJ/m <sup>2</sup> Compartment >2,500m <sup>2</sup> Increase travel distance 25%	>3,500m <sup>2</sup> & fire load >850 MJ/m <sup>2</sup> Max. compartment sizes further reduced if the fire load is higher or the building adjoins other buildings Double compartments and reduce structural fire resistance		Required if top floor >28m Increase travel distance 25%	Required if top floor >28m Increase travel distance 25%	Increase travel distance 25%	Increase travel distance 25%	Top floor >80m	Top floor >80m Increase travel distance 25%	In automatic car parks
Sweden	Yes	Performance-based code	Performance-based code	>800 MJ/m <sup>2</sup> and >5,000m <sup>2</sup>	>800 MJ/m <sup>2</sup> and >2,500m <sup>2</sup>	Performance-based but many hotels sprinklered	All new care homes	All new hospitals	Performance-based code	>16 storey buildings and others for performance	>16 storey buildings and others for performance	Performance-based code
Switzerland		Reduction of 30' in compartment fire resistance	Required in department stores and shopping centres >2,400m <sup>2</sup>	Reduction of 30' in compartment fire resistance	Reduction of 30' in compartment fire resistance	Reduction of 30' in compartment fire resistance	Reduction of 30' in compartment fire resistance	Reduction of 30' in compartment fire resistance	Reduction of 30' in compartment fire resistance		Atria >11m, or >3 storeys, or forming compartment >3,600m <sup>2</sup>	Underground comp'nt: >4,800m <sup>2</sup> single level >2,400m <sup>2</sup> multi-level Above ground: >4,800m <sup>2</sup> closed >9,600m <sup>2</sup> per level open Automatic car parks with >50 cars
Turkey		Museums, entertainment, eating and drinking places >4,000m <sup>2</sup> ; other assembly places >6,000m <sup>2</sup>	Multi-storey with area >2,000m <sup>2</sup> (new); multi- storey with area >3,000m <sup>2</sup> (existing)	>15,000m <sup>2</sup> , or with easily ignitable and flammable materials >6,000m <sup>2</sup>	>5,000m <sup>2</sup> , or with easily ignitable and flammable materials >1,000m <sup>2</sup>	>21.50m (new); or multi-storey with 100 bedrooms (new) or 200 beds (new and existing)	If higher than 30.50m or >1,500m <sup>2</sup>	If higher than 30.50m or >1,500m <sup>2</sup>	If higher than 30.50m	If higher than 51.50m	If new offices higher than 30.50m and in existing offices higher than 51.50m	Enclosed car parks >600m <sup>2</sup> (new) or
United Kingdom	No	If top floor >30m with phased evacuation Multi-storey compartment doubled to 4,000m <sup>2</sup> Structural fire resistance reduced 30' if height <50m or 18m< height <30m. Scotland entertainment compartment >2,000m <sup>2</sup>	In England and Wales for compartments >2000m <sup>2</sup> Sprinkler store room or separate from retail area. Structural fire resistance reduced 30' if height <5m or 18m< height <30m. Required in all Scottish shopping centres	Double max. area per level in multi-floor building to 14,000m <sup>2</sup> if <18m high 4,000m <sup>2</sup> if >18m high. Instead of fire resistance for gallery >10m wide. Structural fire resistance reduced 30' if height <30m.	>20,000m <sup>2</sup> or >18m height Double max. volume per level in multi -floor building to 40,000m <sup>3</sup> (<18m ht.) 8,000m <sup>3</sup> (<18m ht.) 30' less structural fire resistance Scotland >14,000 m <sup>2</sup>	If top floor >30m with phased evacuation	Scotland, Wales all care homes England if >1 bed in a room; instead of door closers.	England must consider sprinklers	Schools: all of Wales; all of Scotland; very common after risk analysis in England	Wales all housing Scotland in buildings above 18m high England in: -buildings above 30m -3 storey house with open plan ground floor -four-storey house without 2nd staircase	resistance by 30'	

Turkey has some requirements in existing buildings
Not places of worship, educational establishments, museums